

Resources

PVC Class 160 IPS Plastic Pipe

www.rainbird.com

PVC Class 160 IPS Plastic Pipe

(1120, 1220) SDR 26 C=150

psi Loss per 100 Feet of Pipe (psi/100 ft.)

Sizes 1" through 6" Flow 1 through 600 gpm

| Nominal Size | 1" | 1 1/4" | 1 1/2" | 2" | 2 1/2" | 3" | 4" | 6" |
|--------------|-----------------|------------|-----------------|------------|-----------------|------------|-----------------|------------|
| Pipe OD | 1.315 | 1.660 | 1.900 | 2.375 | 2.875 | 3.500 | 4.500 | 6.625 |
| Avg. ID | 1.175 | 1.512 | 1.734 | 2.173 | 2.635 | 3.21 | 4.134 | 6.084 |
| Avg. Wall | 0.070 | 0.074 | 0.083 | 0.101 | 0.120 | 0.145 | 0.183 | 0.271 |
| Tolerance | 0.020 | 0.020 | 0.020 | 0.020 | 0.020 | 0.020 | 0.020 | 0.031 |
| Min. Wall | 0.060 | 0.064 | 0.073 | 0.091 | 0.110 | 0.135 | 0.173 | 0.255 |
| Flow (gpm) | Velocity (ft/s) | Loss (psi) |
| 1 | 0.30 | 0.02 | 0.18 | 0.01 | 0.14 | 0.00 | 0.09 | 0.00 |
| 2 | 0.59 | 0.07 | 0.36 | 0.02 | 0.27 | 0.01 | 0.17 | 0.00 |
| 3 | 0.89 | 0.15 | 0.54 | 0.04 | 0.41 | 0.02 | 0.26 | 0.00 |
| 4 | 1.18 | 0.25 | 0.71 | 0.07 | 0.54 | 0.04 | 0.35 | 0.00 |
| 5 | 1.48 | 0.38 | 0.89 | 0.11 | 0.68 | 0.06 | 0.43 | 0.02 |
| 6 | 1.77 | 0.54 | 1.07 | 0.16 | 0.81 | 0.08 | 0.52 | 0.03 |
| 7 | 2.07 | 0.71 | 1.25 | 0.21 | 0.95 | 0.11 | 0.60 | 0.04 |
| 8 | 2.36 | 0.91 | 1.43 | 0.27 | 1.09 | 0.14 | 0.69 | 0.05 |
| 9 | 2.66 | 1.14 | 1.61 | 0.33 | 1.22 | 0.17 | 0.78 | 0.06 |
| 10 | 2.96 | 1.38 | 1.78 | 0.40 | 1.36 | 0.21 | 0.86 | 0.07 |
| 11 | 3.25 | 1.65 | 1.96 | 0.48 | 1.49 | 0.25 | 0.95 | 0.08 |
| 12 | 3.55 | 1.94 | 2.14 | 0.57 | 1.63 | 0.29 | 1.04 | 0.10 |
| 14 | 4.14 | 2.58 | 2.50 | 0.76 | 1.90 | 0.39 | 1.21 | 0.13 |
| 16 | 4.73 | 3.30 | 2.86 | 0.97 | 2.17 | 0.50 | 1.38 | 0.17 |
| 18 | 5.32 | 4.10 | 3.21 | 1.20 | 2.44 | 0.62 | 1.56 | 0.21 |
| 20 | 5.91 | 4.99 | 3.57 | 1.46 | 2.71 | 0.75 | 1.73 | 0.25 |
| 22 | 6.50 | 5.95 | 3.93 | 1.74 | 2.99 | 0.90 | 1.90 | 0.30 |
| 24 | 7.09 | 6.99 | 4.28 | 2.05 | 3.26 | 1.05 | 2.07 | 0.35 |
| 26 | 7.68 | 8.11 | 4.64 | 2.38 | 3.53 | 1.22 | 2.25 | 0.41 |
| 28 | 8.27 | 9.30 | 5.00 | 2.73 | 3.80 | 1.40 | 2.42 | 0.47 |
| 30 | 8.87 | 10.57 | 5.35 | 3.10 | 4.07 | 1.59 | 2.59 | 0.53 |
| 35 | 10.34 | 14.06 | 6.25 | 4.12 | 4.75 | 2.12 | 3.02 | 0.71 |
| 40 | 11.82 | 18.00 | 7.14 | 5.28 | 5.43 | 2.71 | 3.46 | 0.90 |
| 45 | 13.30 | 22.39 | 8.03 | 6.56 | 6.11 | 3.37 | 3.89 | 1.12 |
| 50 | 14.78 | 27.21 | 8.92 | 7.98 | 6.78 | 4.10 | 4.32 | 1.37 |
| 55 | | 9.82 | 9.52 | 7.46 | 4.89 | 4.75 | 1.63 | 3.23 |
| 60 | | 10.71 | 11.18 | 8.14 | 5.74 | 5.18 | 1.91 | 3.53 |
| 65 | | | 11.60 | 12.97 | 8.82 | 6.66 | 5.62 | 2.22 |
| 70 | | | 12.49 | 14.88 | 9.50 | 7.64 | 6.05 | 2.55 |
| 75 | | | 13.38 | 16.90 | 10.18 | 8.68 | 6.48 | 2.89 |
| 80 | | | 14.28 | 19.05 | 10.86 | 9.78 | 6.91 | 3.26 |
| 85 | | | | 11.53 | 10.94 | 7.34 | 3.65 | 4.99 |
| 90 | | | | 12.21 | 12.16 | 7.78 | 4.06 | 5.29 |
| 95 | | | | 12.89 | 13.45 | 8.21 | 4.48 | 5.58 |
| 100 | | | | 13.57 | 14.79 | 8.64 | 4.93 | 5.88 |
| 110 | | | | 14.93 | 17.64 | 9.50 | 5.88 | 6.46 |
| 120 | | | | | 10.37 | 6.91 | 7.05 | 2.71 |
| 130 | | | | | 11.23 | 8.02 | 7.64 | 3.14 |
| 140 | | | | | 12.10 | 9.20 | 8.23 | 3.60 |
| 150 | | | | | 12.96 | 10.45 | 8.81 | 4.09 |
| 160 | | | | | 13.82 | 11.77 | 9.40 | 4.61 |
| 170 | | | | | 14.69 | 13.17 | 9.99 | 5.16 |
| 180 | | | | | | 10.58 | 5.73 | 7.13 |
| 190 | | | | | | 11.16 | 6.34 | 7.52 |
| 200 | | | | | | 11.75 | 6.97 | 7.92 |
| 225 | | | | | | 13.22 | 8.67 | 8.91 |
| 250 | | | | | | 14.69 | 10.53 | 9.90 |
| 275 | | | | | | | 10.89 | 4.81 |
| 300 | | | | | | | 11.88 | 5.65 |
| 325 | | | | | | | 12.87 | 6.55 |
| 350 | | | | | | | 13.86 | 7.52 |
| 375 | | | | | | | 14.85 | 8.54 |
| 400 | | | | | | | | 9.55 |
| 425 | | | | | | | | 10.15 |
| 450 | | | | | | | | 10.74 |
| 475 | | | | | | | | 11.34 |
| 500 | | | | | | | | 11.94 |
| 550 | | | | | | | | 13.13 |
| 600 | | | | | | | | 14.32 |

Note: Dark shaded area of chart indicates velocities over 5' per second. Use with caution

The velocity values were derived using the following equation: $V = \frac{0.408 \times Q_{\text{gpm}}}{d^2}$

Table are based upon the following Hazen-Williams equation: $H_f = 0.2083 \times \left(\frac{100}{C}\right)^{1.852} \times \frac{Q^{1.852}}{D^{4.8655}}$ for change in psi per foot of elevation. Pressure loss for uphill elevation and pressure gain for downhill elevation changes.