



THREADED INLET SIZE: 1 1/4" - ACME
DO NOT USE TEFLON TAPE WITH ACME THREADS
DO NOT USE PIPE DOPE

NOTES:

1. AT ALL SPLICE LOCATIONS, PROVIDE SUFFICIENT SLACK TO ALLOW THE SPLICE TO BE RAISED A MINIMUM OF 24" ABOVE GRADE FOR INSPECTION.
2. THE LOCATION OF THE WIRE CONNECTIONS SHALL BE SNUGLY PLACED BENEATH THE FLANGE OF THE ROTOR.

RAIN BIRD UNITIZED SWING JOINT
ADJUST ANGLE OF SWING JOINT LAY ARM
BETWEEN 30° TO 45° TO ALLOW ADEQUATE
IMPACT ABSORPTION.

MAXI-CABLE COLOR PER SPEC.

SADDLE FOR
HDPE PIPE

RAIN BIRD 700/751 IC ROTOR ON TOP MOUNT SADDLE

NOT TO SCALE

