



- NOTES:
1. GROUND PLATE SHALL BE INSTALLED 30" (IN.) BELOW GRADE.
 2. ENCASE GROUND PLATE IN 100 LBS. OF EARTH CONTACT MATERIAL - 50 LBS. BELOW PLATE AND 50 LBS. ABOVE PLATE. SPREAD CONTACT MATERIAL EVENLY.
 3. NO OTHER WIRES OR CABLES SHALL BE INSTALLED WITHIN THE SPHERE OF INFLUENCE.

**ENHANCED GROUNDING DETAIL
GROUND ROD AND GROUND PLATE
TOP VIEW**

NOT TO SCALE

