



NOTES:

1. ROTORS WIRED INDIVIDUALLY TO SEPARATE DECODER OUTPUTS.
2. AT ALL SPLICE LOCATIONS, INCLUDING DECODERS AND SOLENOIDS, PROVIDE SUFFICIENT SLACK TO ALLOW THE SPLICE TO BE RAISED A MINIMUM OF 24" ABOVE GRADE FOR INSPECTION!
3. THE LOCATION OF WIRE CONNECTIONS SHALL BE SINGLY PLACED BENEATH THE FLANGE OF THE ROTOR.
4. LOCATION OF DECODER IS FOR GRAPHICAL PURPOSES. LOCATION OF DECODER AND SPLICES SHALL BE POSITIONED CLOSE TO SPRINKLER CASE AT TIME OF INSTALLATION.

FD-202 ACTIVATING TWO VALVE-IN-HEAD ROTORS

NOT TO SCALE

